



Calibration Services
 9290 SW Nimbus Ave
 Beaverton, Oregon 97008
 USA



Calibration Cert #2527.01

Calibration Report

Accredited Calibration

Report Number: XXXXXXXXXX-XXXXXX-X

Model: APx511 **Data Type:** AS SHIPPED, NEW **Program:**
Serial Number: XXXXXXXXXX **Date of Cal:** 2-Apr-2026 APxCalibration.exe 24.01

Internal Module Status and Data			
AP Name	Description	Serial No.	Revision
FXAN	Main Board	XXXXXX	702

Explanatory notes to the last three columns of the calibration report

"MU" - The column labeled "MU" lists the expanded measurement uncertainties derived from equipment specifications, repeatability data, and other significant sources. These are stated at a minimum confidence of 95% using a coverage factor k=2 (except as appropriate) following the recommendations in ISO/IEC 98-3 *Guide to the expression of uncertainty in measurement (GUM:1995)*, BIPM JCGM 100:2008, and NIST Technical Note 1297.

"TUR" - The column labeled "TUR" lists the test uncertainty ratio calculated by dividing the lesser of the lower and upper reading tolerances by the 95% expanded measurement uncertainty. An entry of "na" indicates [1] the specified limits are one-sided, or [2] the performance characteristic is not accredited.

"Result" - The column labeled "Result" lists color-coded assessments that the observed characteristic is within its specified limits of performance. There are three possible indications:

pass -- The READING is within the specified upper and lower limits reduced by guard-bands equal to the 95% expanded measurement uncertainty. The probability or risk of false acceptance is very low, typically <0.2%.

uncertain -- The READING is within the specified upper and lower limits, but it is close to one of the limits by an amount that is less than the 95% expanded measurement uncertainty. The probability or risk of false acceptance is elevated.

>> FAIL << -- The READING is outside of the specified limit range.

Accredited measurements listed in the following pages correlate to Audio Precision's Scope of Accreditation as noted:

- note 1 - Frequency Measurement
- note 2 - AC Voltage Measurement
- note 3 - AC Flatness Measurement
- note 4 - Resistance Measurement
- note 5 - DC Voltage Measurement
- note 6 - AC Voltage Source and AC Flatness Source for testing AC Measurement Equipment
- note 7 - DC Voltage Source for testing DC Measurement Equipment

This report is valid only when accompanied by a signed Certificate of Calibration.

Item	Setting(s)	Lower Limit	READING	Upper Limit	MU	TUR	Result
SPEAKER AMPLIFIER CHARACTERISTICS							
[1] Speaker Output Frequency Accuracy (Hz) - note 1							
	10 kHz	9999.9700	9999.9861	10000.0300	0.0064	4.7	pass
[2] Frequency Measurement Accuracy (uHz/Hz) - note 1							
	10 kHz	-3.00	1.39	3.00	0.64	4.7	pass
[3] Speaker Output Amplitude Accuracy, no load, 1 kHz (Volts, mVolts) - note 2							
	5.700 V	5.6673	5.7008	5.7329	0.0016	≥10	pass
	2.000 V	1.9885	2.0012	2.0115	0.0007	≥10	pass
	0.500 V	0.49713	0.50007	0.50289	0.00018	≥10	pass
	100 mV	99.426	100.012	100.577	0.038	≥10	pass
	12 mV	11.931	12.005	12.069	0.013	5.3	pass
[4] Speaker Output Flatness, 8 Ohm load, 1.15 Vrms (dB) - note 3							
	100 Hz	-0.0500	-0.0024	0.0500	0.0014	≥10	pass
	1 kHz	-0.0500	-0.0001	0.0500	0.0013	≥10	pass
	10 kHz	-0.0500	0.0078	0.0500	0.0020	≥10	pass
	20 kHz	-0.1000	0.0358	0.1000	0.0021	≥10	pass
[5] Speaker Voltage Measurement Error, no load, 1 kHz (Volts, mVolts) - note 2							
	5.700 V	-0.0327	-0.0002	0.0329	0.0020	≥10	pass
	2.000 V	-0.0115	0.0001	0.0115	0.0009	≥10	pass
	0.500 V	-0.00287	0.00003	0.00289	0.00018	≥10	pass
	100 mV	-0.574	0.011	0.577	0.038	≥10	pass
	12 mV	-0.069	-0.003	0.069	0.006	≥10	pass
[6] Speaker Voltage Measurement Flatness, 8 Ohm load, 1.15 Vrms (dB) - note 3							
	100 Hz	-0.0500	0.0000	0.0500	0.0020	≥10	pass
	1 kHz	-0.0500	-0.0001	0.0500	0.0020	≥10	pass
	10 kHz	-0.0500	0.0007	0.0500	0.0023	≥10	pass
	20 kHz	-0.1000	0.0023	0.1000	0.0023	≥10	pass
TELECOIL AMPLIFIER CHARACTERISTICS							
[7] Telecoil Output Amplitude Accuracy, 4 Ohm load, 1 kHz (mAmps) - note 2							
	110 mA	108.74	110.07	111.27	0.26	4.8	pass
	50 mA	49.43	50.06	50.58	0.12	4.8	pass
	20 mA	19.771	20.014	20.232	0.049	4.7	pass
	3 mA	2.9657	3.0028	3.0347	0.0074	4.6	pass
[8] Telecoil Output Flatness, 4 Ohm load, 110 mAmps (dB) - note 3							
	100 Hz	-0.0500	-0.0019	0.0500	0.0014	≥10	pass
	1 kHz	-0.0500	0.0000	0.0500	0.0013	≥10	pass
	10 kHz	-0.0500	0.0062	0.0500	0.0020	≥10	pass
	20 kHz	-0.1000	0.0294	0.1000	0.0021	≥10	pass
[9] Telecoil Current Measurement Error, 4 Ohm load, 1 kHz (mAmps) - note 2							
	110 mA	-1.26	-0.15	1.27	0.26	4.8	pass
	50 mA	-0.57	-0.06	0.58	0.12	4.8	pass
	20 mA	-0.229	-0.024	0.232	0.049	4.7	pass
	3 mA	-0.0343	-0.0039	0.0347	0.0074	4.6	pass
[10] Telecoil Current Measurement Flatness, 4 Ohm load, 110 mAmps (dB) - note 3							
	100 Hz	-0.0500	0.0003	0.0500	0.0020	≥10	pass
	1 kHz	-0.0500	0.0000	0.0500	0.0020	≥10	pass
	10 kHz	-0.0500	0.0028	0.0500	0.0023	≥10	pass
	20 kHz	-0.1000	0.0100	0.1000	0.0023	≥10	pass

Item	Setting(s)	Lower Limit	READING	Upper Limit	MU	TUR	Result
BATTERY SIMULATOR CHARACTERISTICS							
[11] Battery Voltage Generation Accuracy, no load (Volts) - note 5							
	2.048 V	2.0330	2.0462	2.0630	0.0004	≥10	pass
	1.3 V	1.2850	1.3002	1.3150	0.0003	≥10	pass
	0.5 V	0.4850	0.5004	0.5150	0.0001	≥10	pass
[12] Battery Voltage Measurement Error, no load (Volts) - note 5							
	2.048 V	-0.0168	-0.0002	0.0168	0.0012	≥10	pass
	1.3 V	-0.0116	-0.0001	0.0116	0.0008	≥10	pass
	0.5 V	-0.0045	0.0000	0.0045	0.0003	≥10	pass
[13] Battery Current Measurement Error, 62 Ohm load (mAmps) - note 5							
	30.00 mA	-1.50	0.11	1.50	0.13	≥10	pass
	3.000 mA	-0.150	0.011	0.150	0.013	≥10	pass
	0.3000 mA	-0.015	0.001	0.015	0.001	≥10	pass
MICROPHONE INPUT CHARACTERISTICS							
[14] DC Measurement Accuracy (Volts, mVolts) - note 7							
	+24 V	23.807	23.993	24.193	0.014	≥10	pass
	+8.0 V	7.9360	7.9978	8.0640	0.0048	≥10	pass
	+2.5 V	2.4800	2.4993	2.5200	0.0015	≥10	pass
	+800 mV	793.40	799.82	806.60	0.48	≥10	pass
	+250 mV	247.25	249.93	252.75	0.15	≥10	pass
	0 mV	-1.000	0.019	1.000	0.046	≥10	pass
	-250 mV	-252.75	-249.88	-247.25	0.15	≥10	pass
	-800 mV	-806.60	-799.76	-793.40	0.48	≥10	pass
	-2.5 V	-2.5200	-2.4993	-2.4800	0.0015	≥10	pass
	-8 V	-8.0640	-7.9979	-7.9360	0.0048	≥10	pass
	-24 V	-24.193	-23.995	-23.807	0.014	≥10	pass
[15] Level Meter AC Accuracy, 1 kHz (Volts, mVolts) - note 6							
	16.9 V	16.803	16.886	16.998	0.009	≥10	pass
	10 V	9.943	9.992	10.058	0.006	9.7	pass
	5 V	4.9713	4.9959	5.0289	0.0029	≥10	pass
	2 V	1.9885	1.9984	2.0115	0.0011	≥10	pass
	500 mV	497.13	499.61	502.89	0.29	10.0	pass
	200 mV	198.85	199.84	201.15	0.11	≥10	pass
	5 mV	4.9713	4.9966	5.0289	0.0031	9.4	pass
[16] Level Meter AC Flatness, 1.15 Vrms (dB) - note 6							
	100 Hz	-0.0500	-0.0171	0.0500	0.0020	≥10	pass
	1 kHz	-0.0500	-0.0001	0.0500	0.0020	≥10	pass
	10 kHz	-0.0500	0.0006	0.0500	0.0023	≥10	pass
	20 kHz	-0.1000	0.0023	0.1000	0.0023	≥10	pass

Item	Setting(s)	Lower Limit	READING	Upper Limit	MU	TUR	Result
NON-ACCREDITED CHARACTERISTICS							
[17] Residual Noise, Microphone Input, 20k BW (uVolts) - non-accredited, self-test							
<i>input shorted</i>		0	1.12	1.40	0.06	na	pass
[18] Sine THD+N (dB), 20 kHz BW - non-accredited, self-test							
<i>Speaker Voltage, Maximum output into 8 Ohms</i>	100 Hz	-999	-106.9	-80.0	1.0	na	pass
	5 kHz	-999	-91.8	-80.0	1.0	na	pass
	20 kHz	-999	-106.6	-80.0	1.5	na	pass
<i>Telecoil Current, 110mA output into 4 Ohms</i>	100 Hz	-999	-109.2	-80.0	1.0	na	pass
	5 kHz	-999	-97.6	-80.0	1.0	na	pass
	20 kHz	-999	-109.7	-80.0	1.5	na	pass
<i>Speaker Output into Microphone Input, 1Vrms</i>	100 Hz	-999	-100.8	-80.0	1.0	na	pass
	5 kHz	-999	-100.5	-80.0	1.0	na	pass
	20 kHz	-999	-100.2	-80.0	1.5	na	pass
[19] Residual SMPTE IMD (%), 4:1, 100Hz:7kHz - non-accredited, self-test							
<i>Speaker</i>	Maximum Output	0%	0.00202%	0.01000%	0.00030%	na	pass
<i>Telecoil</i>	110 mA	0%	0.00076%	0.01000%	0.00030%	na	pass
<i>Microphone</i>	1 Vrms	0%	0.00069%	0.01000%	0.00030%	na	pass
[20] Residual MOD IMD (%), 4:1, 100Hz:7kHz - non-accredited, self-test							
<i>Speaker</i>	Maximum Output	0%	0.00461%	0.01000%	0.00020%	na	pass
<i>Telecoil</i>	110 mA	0%	0.00285%	0.01000%	0.00020%	na	pass
<i>Microphone</i>	1 Vrms	0%	0.00051%	0.01000%	0.00020%	na	pass
[21] Residual DFD IMD (%), mean 8.0kHz, diff 500Hz - non-accredited, self-test							
<i>Speaker</i>	Maximum Output	0%	0.00129%	0.01000%	0.00020%	na	pass
<i>Telecoil</i>	110 mA	0%	0.00082%	0.01000%	0.00020%	na	pass
<i>Microphone</i>	1 Vrms	0%	0.00010%	0.01000%	0.00020%	na	pass

END OF REPORT